

6542 Bungalow was tested and met the following flammability requirements:

ASTM E 84 Adhered Class A